

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 26/12/2024

It is certified that an inspection team headed by Prasen Migan (Health officer)
 (Name of Officers with designation) from Dr. Sunil Sharma (Health officer)
 (Name of Department/ Office) inspected the SCHOLARS ACADEMY, KOTDWAR
 (Name & Address of the school) on (date of inspection) and found that the
SCHOLARS ACADEMY (Name of school) has safe drinking water
 facilities for the students and members of staff of the institution and is maintaining the hygienic
 sanitation condition in the school building & the campus as per norms prescribed by the Central/
 State/ U.T. Govt.

The above is valid for a period of One year

Signature with Seal:

Name

Designation

Name & Address of the Office / Department :

To

SCHOLARS ACADEMY
PADAMPUR, KOTDWAR

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.



Sub Divisional Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, Kotdwar

Ph (O): 01382 – 222219, E-mail: ujseekotdwar@gmail.com

Test Report ID: 01/UJS/SLWQTML/2024-25

Dated: 23/12/2024

WATER QUALITY TEST REPORT

Name and Address of Organization/ Customer	Scholars Academy Padampur, Devi Road, Kotdwar (Garhwal) Uttarakhand. -246149		
Product Description (Surface Water/ Ground Water/ Drinking Water)	Drinking Water	Sample Description	One Water Sample collected from Scholars Academy Kotdwar
Reference Sample Identification:	SDWQTML/UJSK-001		Date of Start of Analysis: 20/12/2024
			Date of End of Analysis: 23/12/2024
Date and Time of Sample Received: 20/12/24 & 10:15AM	Sample Collected by:	Manish Negi Sample Asist. U.J.S. Kotdwar	

SN	Water Quality Parameters Under Chemical Scope	Results	Desirable Limit (BIS)	Permissible Limit (BIS) in the Absence of alternative source	Std. Test Method
1.	pH	7.01	6.5 to 8.5	No Relaxation	IS 3025 Pt-11, 2017
2.	Total Dissolved Solids (TDS), mg/L	121.4	500	2000	IS 3025 Pt-16-2017
3.	Turbidity, NTU	0.24	1	5	IS 3025 Pt-10-2017
4.	Total Alkalinity (as CaCO ₃), mg/L	80	200	600	IS 3025 Pt-23: 2019
5.	Total Hardness (as CaCO ₃), mg/L	88	200	600	IS 3025 Pt-21: 2002
6.	Chloride, mg/l	11.99	250	1000	IS 3025 Pt-32 : 2019
7.	Calcium (as Ca), mg/L	26.4	75	200	IS 3025 Pt-40 : 2019
8.	Magnesium (as Mg), mg/L	5.35	30	100	APHA 23rd Ed.-3500-Mg B: 2017
9.	Colour, Hazen	Less than 05	5	15	IS 3025 Pt-04 : 2021
10.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 Pt-05 : 2018
11.	Taste	Agreeable	Agreeable	Agreeable	IS 3025 Pt-08 : 2012
(B.) Biological Parameters					
13	E-Coli	Absent	Absent	Absent	MPN
14	Total Coliform	Absent	Absent	Absent	MPN

Remark: Above received water sample conforms to IS: 10500-2012 for drinking purpose with respect to above tests.

Kuldeep Singh
(Chemist)

SUB-DIVISIONAL LEVEL
WATER QUALITY TESTING
MONITORING LABORATORY
U.J.S. KOTDWAR (GARHWAL)

-End of Report-

1. The results listed refer only to tested sample and applicable parameters.

2. This certificate is not to be reproduced wholly or in parts for promotional publicity or legal purpose without permission of authority of testing laboratory.

3. The samples will be destroyed after fifteen days from the date of issue of test certificate, unless otherwise agreed with customer.